

SUSANA MARTINEZ
Governor

JOHN A. SANCHEZ Lieutenant Governor

## State of New Mexico ENVIRONMENT DEPARTMENT Environmental Health Division DRINKING WATER BUREAU

P.O Box 5469 Santa Fe, NM 87502 Tel. 505-476-8629 • Fax 505-476-8656

www.nmenv.state.nm.us/dwb



RYAN FLYNN Cabinet Secretary

BUTCH TONGATE
Deputy Secretary

## CERTIFIED RETURN RECEIPT REQUESTED 7005 1820 0001 5772 1824

April 21, 2014

Yvonne Dickey-Folks Jemez Springs DWUA PO Box 123 Jemez Springs, New Mexico 87025

RE: Administrative Order on Consent, Stipulated Final Order No. 2011-ACO-006 Jemez Springs Domestic Water Users Association, PWS# NM3509123 Request for Extension

Ms. Dickey-Folks:

The New Mexico Environment Department (NMED) Drinking Water Bureau received your request for extension letter dated April 8, 2014. The NMED has reviewed your request and agrees to modify Paragraphs 10 and 11 of Administrative Order on Consent, Stipulated Final Order No. 2011-ACO-006. Paragraph 10 shall be modified to read "by May 31, 2014, be in compliance with 20.7.10.100 NMAC, incorporating 40 C.F.R. § 141.62(b)(16), and provide drinking water with concentrations of Arsenic below the MCL of 0.010 mg/L." Paragraph 11 shall be modified to read "by May 31, 2015, be in compliance with Section 20.7.10.100 NMAC, incorporating 40 C.F.R. § 141.23(i)(1), and have a RAA for Arsenic below the MCL of 0.010 mg/L."

If you have any questions or need assistance, please contact Maria J. Medina, Enforcement Coordinator, at 505-476-8629 or via email at maria.medina@state.nm.us.

Sincerely,

Tom Blaine, Division Director Environmental Health Division

CC: Magneto System File System File

## **CERTIFICATE OF SERVICE**

I hereby certify that a copy of the foregoing letter was sent via certified return receipt requested on the following party of record on  $\frac{9/23}{}$ , 2014.

Yvonne Dickey-Folks Jemez Springs DWUA PO Box 123 Jemez Springs, New Mexico 87025

Maria J. Medina